



State Water Authority
Certificate of Approval for Water Supply Product

The State Water Authority of Sarawak hereby gives approval for this water supply product to be used in the Water Supply Authority areas within Sarawak, under the powers vested in Part III Regulation 9 of the Water Supply Regulations 1995:

Name of Water Supply Product: **VALVE(GATE VALVE)**

Name & Address of Certificate Holder: **TEK VALVE (M) SDN BHD
PT 22432 LOT ASAL 6535 JALAN
SUNGAI PULOH, BATU 5 1/2 , JALAN
KAPAR**

Type: **Fitting**

Nature of Business Entity of Certificate: **Supplier**

Brand: **TEK**

Name & Address of Manufacturer: **QUANZHOU YONGCHUN FENGJI
WATER WARM EQUIPMENT AND
SUPPLIES CO.LTD.**

Standard: **BS 5163-1:2004**

**QUANZHOU YONGCHUN FENGJI
WATER WARM EQUIPMENT AND
SUPPLIES CO.LTD. TAN HUA SHAN
INDUSTRIES AREA, YONGCHUN
COUNTY, 362600 QUANZHOU, FUJIAN.
CHINA**

Class & Size: **See schedule on the reverse page**

Validity Period: **06/09/2024** to **09/10/2025**

Name & Address of Principal: **TEK VALVE (M) SDN BHD
PT 22432 LOT ASAL 6535 JALAN
SUNGAI PULOH BATU 5/2,JALAN
KAPAR .42200 KLANG .SELANGOR**

Date of Issue: **06/09/2024**

Product Category: **Category A**

This approval is given subject to the following:

- i. The State Water Authority of Sarawak reverses the right to withdraw this approval at anytime and shall not be obliged to give any reason whatsoever.
- ii. The specifications for the water supply products shall not differ from that originally submitted in the application for approval.
- iii. There should not be any unsuitability in the use of this product.
- iv. This certificate of approval shall not be used for any advertisement purpose. However, a copy can be used as evidence of approval only.
- v. This certificate of approval shall become invalid upon expiry of SPAN Product Certificate Registration or SIRIM Licence or IKRAM Bhd Certification or other internationally recognized certification of the product, whichever is earlier.



Schedule

COMPANY NAME: **TEK VALVE (M) SDN BHD**

PRODUCT: **VALVE(GATE VALVE)**

VALIDITY PERIOD: **06/09/2024 - 09/10/2025**

CERTIFICATE NUMBER: **SWA/F/0692**

Model	Series	Description
TYPE OF BODY = DOUBLE FLANGE ; TRIM = RES ; STEM = SUS 431/29 (NON-RISING) ; BODY = SG (EN-GJS 500-7) ; FACE TO FACE = SERIES 3	SERIES 3 / PN16	DOUBLE FLANGE DUCTILE IRON NON-RISING RESILIENT SEAT SLUICE VALVE PN16 / DN50, DN65, DN80, DN125, DN100, DN150, DN200, DN250, DN300, DN350, DN400, DN450, DN500, DN600 / DOUBLE FLANGE DUCTILE IRON NON-RISING RESILIENT SEAT SLUICE VALVE PN16



State Water Authority
Certificate of Approval for Water Supply Product

The State Water Authority of Sarawak hereby gives approval for this water supply product to be used in the Water Supply Authority areas within Sarawak, under the powers vested in Part III Regulation 9 of the Water Supply Regulations 1995:

Name of Water Supply Product: **VALVE(GATE VALVE)**

Name & Address of Certificate Holder: **TEK VALVE (M) SDN BHD
 PT 22432 LOT ASAL 6535 JALAN SUNGAI PULOH, BATU 5 1/2 , JALAN KAPAR**

Type: **Fitting**

Nature of Business Entity of Certificate: **Supplier**

Brand: **TEK**

Name & Address of Manufacturer: **QUANZHOU YONGCHUN FENGJI WATER WARM EQUIPMENT AND SUPPLIES CO.LTD.**

Standard: **BS EN 1171 :2002**

QUANZHOU YONGCHUN FENGJI WATER -WARM EQUIPMENT AND SUPPLIES CO.LTD. TAN HUA SHAN INDUSTRIAL AREA, YONGCHUN COUNTY 362600 QUANZHOU FUJIAN. CHINA.

Class & Size: **See schedule on the reverse page**

Validity Period: **06/09/2024** to **09/10/2025**

Name & Address of Principal: **TEK VALVE (M) SDN BHD
 PT 22432 LOT ASAL 6535 JALAN SUNGAI PULOH BATU 5 1/2,JALAN KAPAR,42200 KLANG SELANGOR**

Date of Issue: **06/09/2024**

Product Category: **Category A**

This approval is given subject to the following:

- i. The State Water Authority of Sarawak reverses the right to withdraw this approval at anytime and shall not be obliged to give any reason whatsoever.
- ii. The specifications for the water supply products shall not differ from that originally submitted in the application for approval.
- iii. There should not be any unsuitability in the use of this product.
- iv. This certificate of approval shall not be used for any advertisement purpose. However, a copy can be used as evidence of approval only.
- v. This certificate of approval shall become invalid upon expiry of SPAN Product Certificate Registration or SIRIM Licence or IKRAM Bhd Certification or other internationally recognized certification of the product, whichever is earlier.



Schedule

COMPANY NAME: **TEK VALVE (M) SDN BHD**

PRODUCT: **VALVE(GATE VALVE)**

VALIDITY PERIOD: **06/09/2024 - 09/10/2025**

CERTIFICATE NUMBER: **SWA/F/0691**

Model	Series	Description
CAST IRON GATE VALVE ; FLANGED ENDS	SERIES 3 / PN16	TYPE OF BODY : DOUBLE FLANGE ; BODY AND BONNET MATERIAL : EN-GJS-500-7 ; STEM MATERIAL: SS431 ; OBTURATOR SEAT ; EN-GJS-500-7 ENCAPSULATED WITH EPDM ; BODY SEAT : EN-GJS-500-7; TYPE OF COATING : EPOXY; FACE TO FACE : SERIES 3 / DN700, DN800, DN900 / DOUBLE FLANGE DUCTILE IRON NON-RISING RESILIENT SEAT SLUICE VALVE PN16

End of Page



State Water Authority
Certificate of Approval for Water Supply Product

The State Water Authority of Sarawak hereby gives approval for this water supply product to be used in the Water Supply Authority areas within Sarawak, under the powers vested in Part III Regulation 9 of the Water Supply Regulations 1995:

Name of Water Supply Product: **VALVE(GATE VALVE)**

Name & Address of Certificate Holder: **TEK VALVE (M) SDN BHD
PT 22432 LOT ASAL 6535 JALAN SUNGAI PULOH, BATU 5 1/2 , JALAN KAPAR**

Type: **Fitting**

Nature of Business Entity of Certificate: **Supplier**

Brand: **TEK**

Name & Address of Manufacturer: **QUANZHOU YONGCHUN FENGJI WATER WARM EQUIPMENT AND SUPPLIES CO.LTD.**

Standard: **EN 1074-2:2004**

QUANZHOU YONGCHUN FENGJI WATER-WARM EQUIPMENT AND SUPPLIES CO.LTD,TAN HUA SHAN INDUSTRIAL AREA, YONGCHUN COUNTY 362600 QUANZHOU FUJIAN, CHINA.

Class & Size: **See schedule on the reverse page**

Validity Period: **06/09/2024** to **09/10/2025**

Name & Address of Principal: **TEK VALVE (M) SDN BHD
PT 22432 LOT ASAL 6535 JALAN SUNGAI PULOH BATU 5 1/2 JALAN KAPAR,42200 KLANG.SELANGOR.**

Date of Issue: **06/09/2024**

Product Category: **Category A**

This approval is given subject to the following:

- i. The State Water Authority of Sarawak reverses the right to withdraw this approval at anytime and shall not be obliged to give any reason whatsoever.
- ii. The specifications for the water supply products shall not differ from that originally submitted in the application for approval.
- iii. There should not be any unsuitability in the use of this product.
- iv. This certificate of approval shall not be used for any advertisement purpose. However, a copy can be used as evidence of approval only.
- v. This certificate of approval shall become invalid upon expiry of SPAN Product Certificate Registration or SIRIM Licence or IKRAM Bhd Certification or other internationally recognized certification of the product, whichever is earlier.



Schedule

COMPANY NAME: **TEK VALVE (M) SDN BHD**

PRODUCT: **VALVE(GATE VALVE)**

VALIDITY PERIOD: **06/09/2024 - 09/10/2025**

CERTIFICATE NUMBER: **SWA/F/0694**

Model	Series	Description
TYPE OF BODY = DOUBLE FLANGE ; TRIM = LG2 COPPER ALLOY FACE (CF); STEM = SUS 431S29 (NON-RISING) ; BODY = SG (EN GJS 500-7) ; FACE TO FACE = SERIES 3 ; LEAKAGE RATE : B	SERIES 3 / PN16	DOUBLE FLANGE DUCTILE IRON NON-RISING METAL SEAT SLUICE VALVE PN16 / DN1000, DN1100, DN1200, DN1250, DN1300 / DOUBLE FLANGE DUCTILE IRON NON-RISING METAL SEAT SLUICE VALVE PN16
TYPE OF BODY = DOUBLE FLANGE ; TRIM = RES ; STEM = SUS 431S29 (NON-RISING) ; BODY = SG (EN GJS 500-7) ; FACE TO FACE = SERIES 3	SERIES 3 / PN16	DOUBLE FLANGE DUCTILE IRON NON RISING RESILIENT SEAT SLUICE VALVE PN16 / DN50, DN65, DN80, DN100, DN125, DN150, DN200, DN250, DN300, DN350, DN400, DN450, DN500, DN600, DN700, DN800, DN900, DN1000, DN1100, DN1200, DN1400 AND DN1600 / DOUBLE FLANGE DUCTILE IRON NON RISING RESILIENT SEAT SLUICE VALVE PN16