



No Lesen : **PT058902**

Licence No :

LESEN PENSIJILAN BARANGAN *Product Certification Licence*



SIRIM

**SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
*SIRIM QAS International Sdn. Bhd. hereby grants to***

**TEK VALVE (M) SDN. BHD.
PT 22432, LOT ASAL 6535
SUNGAI PULOH BATU 5 1/2
JALAN KAPAR
42450 KLANG
SELANGOR, MALAYSIA**



ACB 001

**Lesen untuk menggunakan Tanda Pensijilan di atas barangan
*a licence to use the Certification Mark on***

AIR VALVE

Please refer to detail in the SCHEDULE

**sebagai mematuhi keperluan
*as complying with***

ANSI/AWWA C 512-15



Nur Fadhilah binti Muhammad
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.



SIRIM QAS International Sdn. Bhd.
(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 603-5544 6000
Emel : cserviceqas@sirim.my

<https://www.sirim-qas.com.my>
<https://www.malaysiancertified.com.my>

Tarikh Mula Pensijilan : 16 June 2009

Certified Since

Sah Sehingga : 09 October 2025

Valid Until

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

Tarikh Dikeluarkan : 07 August 2024

Issue Date

No Siri : 101148

Serial No

SCHEDULE

TEK VALVE (M) SDN. BHD.



Trade Mark : TEK, TEK VALVE
Model : COMBINATION AIR VALVE;
WITHOUT THROTTLING AND WITHOUT SLOW CLOSING DEVICE
Rating : NOMINAL PRESSURE: PN16
Type : VALVE OUTLET: FLANGE; BODY MATERIAL: EN-GJS-500-7; FLOAT MATERIAL:
ABS; TYPE OF COATING: EPOXY; APPLICATION : WATER SERVICE
Size : NOMINAL SIZE: DN50, DN80, DN100, DN150, DN200 AND DN250



Trade Mark : TEK, TEK VALVE
Model : AIR RELEASED VALVE;
WITHOUT THROTTLING AND WITHOUT SLOW CLOSING DEVICE
Rating : NOMINAL PRESSURE: PN16
Type : VALVE OUTLET: FLANGE; BODY MATERIAL: EN-GJS-500-7; FLOAT MATERIAL:
ABS; TYPE OF COATING: EPOXY; APPLICATION : WATER SERVICE
Size : NOMINAL SIZE: DN25 AND DN50



Trade Mark : TEK, TEK VALVE
Model : STANDARD COMBINATION AIR VALVE DESIGN;
WITH SLOW CLOSING DEVICE
Rating : NOMINAL PRESSURE: PN16
Type : VALVE OUTLET: FLANGE; BODY MATERIAL: EN-GJS-500-7; FLOAT MATERIAL:
ABS; TYPE OF COATING: EPOXY; APPLICATION : WATER SERVICE
Size : NOMINAL SIZE: DN50, DN80, DN100, DN150, DN200 AND DN250

Factory Name and Location :
QUANZHOU YONGCHUN FENGJI PLUMBING EQUIPMENT CO LTD
TANHUASHAN INDUSTRIAL AREA,
YONGCHUN
QUANZHOU
FUJIAN, CHINA

End of page

SURUHANJAYA PERKHIDMATAN AIR NEGARA

SIJIL PERAKUAN PENDAFTARAN PEMBEKAL

(SUPPLIER REGISTRATION CERTIFICATION)

Adalah dengan ini diperakui bahawa syarikat dan produk seperti yang tercatat di bawah telah berdaftar dengan Suruhanjaya Perkhidmatan Air Negara bagi kegunaan industri perkhidmatan air di negeri-negeri Semenanjung Malaysia serta Wilayah Persekutuan Putrajaya dan Labuan sahaja.

(This is to certify that the following company and product have been registered with Suruhanjaya Perkhidmatan Air Negara to be used in the water services industry in Peninsular Malaysia and Federal Territory of Putrajaya and Labuan only.)

No. Rujukan Pendaftaran (Reference of Registration No.)	:	10/2024/0261/A/W-179
Alamat Syarikat Pembekal (Name and Address of Supplier)	:	TEK VALVE (M) SDN. BHD., PT 22432, LOT 6535, JALAN SUNGAI PULOH, BATU 5 1/2 42200 KLANG, SELANGOR DARUL EHSAN

MAKLUMAT PRODUK ATAU SISTEM (PARTICULARS OF PRODUCT OR SYSTEM)

Kategori (Category)	:	A - FLOW CONTROL
Nama Produk atau Sistem (Product or System Name)	:	VALVE
Perihal Produk atau Sistem (Product or System Description)	:	Model - Siri: Rujuk perincian model dan spesifikasi di lampiran
Jenama (Brand Name)	:	TEK, TEK VALVE
Piawai (Standard)	:	AWWA C512-15
Kegunaan (Application)	:	SISTEM BEKALAN AIR
Nama dan Alamat Pembuat (Name and Address of Manufacturer)	:	QUANZHOU YONGCHUN FENGJI PLUMBING EQUIPMENT CO. LTD., TANHUASHAN INDUSTRIAL AREA,, YONGCHUN,, QUANZHOU FUJIAN,, CHINA
Nama dan Alamat Prinsipal (Name and Address of Principal)	:	QUANZHOU YONGCHUN FENGJI PLUMBING EQUIPMENT CO. LTD., TANHUASHAN INDUSTRIAL AREA,, YONGCHUN,, QUANZHOU. FUJIAN,, CHINA
Sah Sehingga (Valid Until)	:	19 JUN 2027

Sijil yang dikeluarkan adalah tertakluk kepada SYARAT-SYARAT AM (Bahagian A) dan SYARAT-SYARAT KHUSUS (Bahagian B).
(The Certificate issued is subject to the GENERAL CONDITIONS (Section A) and SPECIFIC CONDITIONS (Section B))

(DATO' HJ. AHMAD FAIZAL BIN ABDUL RAHMAN)
KETUA PEGAWAI EKSEKUTIF
Suruhanjaya Perkhidmatan Air Negara (SPAN)

Tarikh Dikeluarkan
(Issue Date) : 18 JUN 2024



BAHAGIAN A : SYARAT-SYARAT AM

1. Kelulusan ini adalah terpakai di Semenanjung Malaysia serta Wilayah Persekutuan Putrajaya dan Labuan sahaja.
2. SPAN berhak menggantung, membatalkan serta menarik balik kelulusan ini sekiranya:
 - (a) didapati bahawa maklumat yang diberikan oleh pembekal adalah tidak benar;
 - (b) berlaku kemerosotan ke atas kualiti produk;
 - (c) aduan yang diterima daripada mana-mana pihak berkenaan produk yang dibekalkan terbukti benar; pembekal gagal mematuhi keperluan-keperluan yang ditetapkan dalam "Guidelines for Listing and Registration of Products and Suppliers"; dan
 - (e) berlaku perubahan pada tatacara pendaftaran.
4. Penggunaan logo SPAN pada produk atau bahan cetakan adalah tidak dibenarkan. Pembekal boleh menggunakan pernyataan "produk telah didaftarkan dengan SPAN (nombor rujukan pendaftaran)" pada bahan cetakan. Penggunaan pernyataan "dipersijilkan oleh SPAN" atau "diluluskan oleh SPAN" adalah dilarang sama sekali.
5. SPAN boleh menjalankan audit pada bila-bila masa dalam tempoh kelulusan pendaftaran untuk mengukur prestasi produk dan syarikat sebagai asas untuk pembaharuan pendaftaran. Segala kos ujian yang terlibat akan ditanggung oleh pembekal.
6. Pembekal dikehendaki mengemukakan dan mengemaskini senarai rekod pemasangan dan penjualan produk setiap tahun kepada SPAN melalui aplikasi e-Registration.
7. Pembekal dikehendaki mematuhi sebarang arahan yang dikeluarkan oleh SPAN dari masa ke semasa .

BAHAGIAN B : SYARAT-SYARAT KHUSUS

1. O-Ring / Gasket perlu daripada EPDM.
2. Material injap (Body material) perlu daripada Ductile Iron.

LAMPIRAN

No Fail : 10/2024/0261/A/W-179

No. Sijil : SPAN/BPAI/0510-2024

Tarikh : 18 JUN 2024

**PERAKUAN PENYENARAIAAN PEMBEKAL**

PEMBEKAL : TEK VALVE (M) SDN. BHD.
PT 22432, LOT 6535,
JALAN SUNGAI PULOH, BATU 5 1/2
42200 KLANG,
SELANGOR DARUL EHSAN

PRODUK : VALVE

Model-model yang diluluskan oleh SPAN adalah seperti di bawah

No	Model	Series/Rating	Type/Size/Description
1	Combination Air Valve; Without Throttling and Without Slow Closing Device	DOUBLE ORIFICE DUCTILE IRON KINETIC AIR VALVE PN16 / PN16	VALVE OUTLET : FLANGE; BODY MATERIAL : EN-GJS-500-7; FLOAT MATERIAL : ABS; TYPE OF COATING : EPOXY; APPLICATION : WATER SERVICE / DN50, DN80, DN100, DN150, DN200 AND DN250 / DOUBLE ORIFICE DUCTILE IRON KINETIC AIR VALVE PN16
2	Air Released Valve; Without Throttling and Without Slow Closing Device	SINGLE ORIFICE DUCTILE IRON AIR VALVE PN16 / PN16	VALVE OUTLET : FLANGE; BODY MATERIAL : EN-GJS-500-7; FLOAT MATERIAL : ABS; TYPE OF COATING : EPOXY; APPLICATION : WATER SERVICE / DN25 AND DN50 / SINGLE ORIFICE DUCTILE IRON AIR VALVE PN16
3	Standard Combination Air Valve Design; With Slow Closing Device	DOUBLE ORIFICE DUCTILE IRON STANDARD AIR VALVE PN16 / PN16	VALVE OUTLET : FLANGE; BODY MATERIAL : EN-GJS-500-7; FLOAT MATERIAL : ABS; TYPE OF COATING : EPOXY; APPLICATION : WATER SERVICE / DN50, DN80, DN100, DN150, DN200 AND DN250 / DOUBLE ORIFICE DUCTILE IRON STANDARD AIR VALVE PN16